

Declaration of Performance

Certificate No: **HTCDOP-STB3-01**

1. Unique Identification Code of the product type **OM4-24-STB3-01**



2. Type Number allowing the identification of the construction product as required under article 11 is HT-OM4-24-TB-CCA

3. Intended Use: Electrical and communications cable for general applications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

4. Manufacturer: HellermannTyton Data Ltd,
Northampton,
Northamptonshire,
NN5 5JE,
United Kingdom
+44(0)1604 706633
www.htdata.co.uk

5. Authorised Representative: N/A

6. AVCP method: System 1+
Harmonised standard EN 50575 : 2014+A1 2016

7. *Notified product certification body No. 3P (2652) performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.*

8. Declaration of Performance

Essential Characteristics	Performance	Harmonised Technical Standard
Reaction to fire	Class Cca s1a, d1, a1	EN 50575 :2 014+A1 2016
Dangerous Substances	NPD	

9. The performance of the product identified in points 1 and 2 above is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4 above

Signed on behalf of HellermannTyton

Matthew Hunter, Managing Director

Print Name and Position

Signed:

Northampton NN5 5JE United Kingdom, 01/11/2022

Date and Place