



We help ideas meet the real world



Compliance Statement

No. 2009-169

Screened Permanent Link, Class E_A for 10GBASE-T

Company

HellermannTyton Data Limited
Cornwell Business Park
Salthouse Rd
Brackmills, Northampton, NN4 7EX
United Kingdom

Permanent Link Identification (2 connector model)

Horizontal cable:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Cable

Telecommunications Outlet:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Keystone Outlet

Generic cabling standards, cabling components standard

- Draft amendment 2 to ISO/IEC 11801:2002 (JTC 1/SC 25N1599)
- EN 50173:2007
- ISO/IEC TR 24750
- ANSI/TIA/EIA-568B.2-10 Category 6A
- ANSI/TIA/EIA TSB-155

Technical report

DELTA-N312633, DANAK-19J2116

Manufacturer code

1901A

Certificate valid until

13 November 2010

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 13 August 2009

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable



TEST Reg. no. 19